

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/WZ/2024/ 224

Dated: 29/04/2024

To,

The Authorized Signatory,  
Plot No. 16 A, Najafgarh Road,  
Industrial Area, New Delhi.

Subject: **Regarding issuance of fire safety certificate in r/o Plot No. 16 A, Najafgarh Road, Industrial Area, New Delhi.**

Sir,

Please refer to letter dated. nil, received through outdoor diary no. 13059 dated 13/02/2024, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officers concerned of this department on 28/03/2024 in the presence of Sh. Niranjana to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the said building is comprised of Basement, Ground plus 3 upper floors. Fire safety arrangements such as fire extinguishers, first-aid hose reel, MOEFA, internal hydrant, pumping arrangements, water storage tank etc. have been provided in the building. However the following shortcomings were observed.

1. Fire Check Doors are not provided.
2. Smoke management system is provided but not-functional.
3. Ground level pumps are not on auto mode.
4. Exit signages are not provided.

In view of above shortcomings the application for issuance of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The license issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire Safety arrangements.

Yours faithfully,

(Atul Garg)

Director

Copy To:

1. The Executive Engineer (Bldg.) HQ, North Delhi Municipal Corporation, 8<sup>th</sup> floor, Minto Road, New Delhi.

26/4/2024