

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 198

Dated: 30 /04 /2024

To,

The Principal
Rajkiya Sarvodaya Vidyalaya No-4,
Roop Nagar, Delhi-110007.

Sub:- Regarding renewal of fire safety certificate in r/o Rajkiya Sarvodaya Vidyalaya No-4, Roop Nagar, Delhi-110007. (School I.D-1207013)

Please refer to your letter no. RSVNO4/RN/2024/12 dated 05.04.2024 received in this department vide outdoor dairy no.369 dated 08.04.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 24.04.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 04 blocks, 03 block comprised of ground + first floor & 01 block comprised of ground + 03 upper floors only ground & 03 upper floors only. At the time of inspection Sh. Karambir (Estate Manager) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguisher is provided but found not functional the time of inspection.

2. Hose reel hose is provided but not functional at the time of inspection and some nozzles found missing.

3. Internal hydrant is provided but found not functional.

4. Terrace level fire pump capacity of 450 LPM is provided but found not functional.

5. Terrace level fire water tank capacity of 10,000ltr is provided but found empty.

6. Exit signage's found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this departments till such time running of school is at your own risk & responsibility.

Yours faithfully

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054