

c/76

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ | 154

Dated: 25/04/2024

To

The Addl. Commissioner of Police,
Lic Branch, 1st Floor, PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Rooh (A Unit of Aveenashi Hospitality Pvt. Ltd) H-5/1, FF, Kalka Das Marg Main Road, Mehrauli, New Delhi-110030

Sir,

This is in reference to with **MHA Portal ID 2024031803196** dated **29/03/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.04.2024 in the presence of Mr. Gaurav Singh to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid Hose reel hose provided but found non-functional.
2. Internal Hydrants provided but found non-functional.
3. Terrace level fire fighting pumps provided but found non-functional.
4. Exit Signage found removed at some places.
5. The restaurant is also running at 2nd floor, where the application is received for 1st floor only.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE