

c/92

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/184
To

Dated: 30/4/2024

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s TE New Delhi (Unit of TE Hospitality And Estates Ltd) at A-3 Pamposh Enclave, Greater Kailash-1, New Delhi 110048.

Sir,

This has reference with **MHA Portal ID 2024041204850 Dated 12-04-2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 22.04.2024 in the presence of Sh. Umesh Kumar (Manager) of the Guest House. Accordingly fire safety arrangement were tested / checked and found following observation:

1. Fire check doors found removed at stilt floor.
2. Smoke management system provided but found nonfunctional.
3. Carbon Monoxide detector provided but found nonfunctional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

du w