

962

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/187

Dated: 01/05/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/S Al - Sana Guest House situated at 8-12 to 15, SF & TF, Bazar Matiya Mahal, Jama Masjid, Delhi-06.

Sir,

This has reference to online application I.D. no. 2024040604345 dated 08.04.2024 on the subject cited above. In this connection, it is informed that the guest house was inspected by the officer concerned of this department on 25.04.2024 in the presence Mohd. Javed (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Exhaust fan for smoke management system not provided.
2. Fire extinguishers found non functional.
3. CO detectors provided but not functional.
4. LPG bank at terrace of third floor is not allowed as per clause 7.3.1 of UBBL-2016.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service 011

Tel: 011-23414900

01/05/24
21/4

Copy to:-

The Manager,

Al - Sana Guest House at 8-12 to 15, SF & TF, Bazar Matiya Mahal, Jama Masjid, Delhi-06.