



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2024/Incl./ 230

Dated: 01/05/2024

To

Sh. Gaurav Dutta  
Plot No. 46, at, SSI, Indl. Area,  
G.T. Karnal Road, Delhi-110033.

Sub: Regarding issuance of Fire Safety Certificate in r/o Biotic Waste Solution located at Plot No. 46, SSI, Industrial Area, G.T. Karnal Road Delhi-110033.

Sir,

Please refer to your letter no. nil dated 11.04.2024 received in this department vide outdoor diary no. 514 dated 12.04.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26.04.2021 to verify the fire safety arrangements installed in the building as per issued fire safety recommendations vide letter of even no. F6/DFS/MS/BP/2006/1483 dated 05.07.2006 at the time of inspection Mr. Abhishek (Manager) was also present at site. During the course of the inspection it is observed that the building is comprised of Ground floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. The main entrance gate width of 3.80m is provided against the requirement of 05m
2. All doors size width of 01m is provided against the requirement of 1.25m.
3. Hose reel hose is not provided.
4. MOEFA system is not provided.
5. PA system is not provided
6. Sprinkler systems is not provided.
7. Terrace level fire pump capacity of 900lpm is not provided.
8. Terrace level fire water tank capacity of 10,000ltrs is not provided.
9. Exit signage's is not provided.
10. Standby power supply is not provided.


Keeping in view of above, issuance of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of industry is at your own risk & responsibility.

Yours faithfully

  
(Atul Garg)  
Director  
Ph:-011-23414000

Copy to:-

1. The Dy. Commissioner of Factory licensing, SDMC 3rd, Floor, Civic Centre Minto Road, Delhi-110002.

  
30/5