



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

75
आज़ादी का
अमृत महोत्सव

Dated: 03/05/2024

No. F. 6. / DFS / MS / BP / 2024/ 234

To,

The Authorized Signatory,
Commander Hospital,
Plot No. 55, 56, 57, Shiv Vihar West,
Vikas Nagar, New Delhi – 110059.

Sir,

Please refer your letter No. Nil dated 01.04.2024. In this connection it is to inform you that the as-built building plan, submitted by you, has been examined from fire safety point of view and observed following shortcomings:

1. Width of staircases is not marked on the plan.
2. Entry to lift and staircases is not through Fire Check Door.
3. Door / window schedule is not provided.
4. Terrace and layout plan is not provided.
5. Fire-fighting arrangements, as stipulated in NBC-Part-4, 2016 are not marked on plans.
6. Area chart is not provided.
8. Year of registration / construction is not provided.

Therefore, the plan is returned to you in original with request to provide above information for further consideration in the matter.

Yours faithfully


31/05/24

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Ph.: 011-23414000

