

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

deo

No.F6/DFS/MS/SZ/2024/190

Dated: 2 15 /2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/s Guest House Clark Heights
Located at 1/1, West Patel Nagar, New Delhi-110008.**

Sir,

Please refer to online application No. 2024040904594, dated 12/04/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 30/04/2024 in the presence of Sh. Manoj Singh (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. The staircase/ exit passage are not ventilated properly.
2. Hose reel hose found nonfunctional.
3. MOEFA and PA system found not nonfunctional.
4. Automatic sprinkler system found nonfunctional in basement.
5. Terrace pump of 450 lpm capacity found nonfunctional & main valve found closed at terrace.
6. Communication system in lift car found nonfunctional.
7. The corridor floors/ passage found decorated with flammable material.
8. Diesel tank for boiler found installed in staircases.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service
West Patel Nagar

Copy to: - The Manager, M/s Guest House Clark Heights Located at 1/1, West Patel Nagar
New Delhi-110008.

30/4/24