

999

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/193

Dated: 02/05/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/S Seema Lodge** located at **3745, Churiwalan, Chawri Bazar, Delhi- 06.**

Sir,

This has reference to online application I.D. no. 2024040804424 dated 15.04.2024 on the subject cited above. In this connection, it is informed that the guest house was inspected by the officer concerned of this department on 26.04.2024 in the presence Mohd. Akhlaq (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire check doors provided but not sealed properly & location of installation point is wrong at 1st floor.
2. CO detectors with panel provided but not functional.
3. Public address system not provided.
4. Fire pump not in auto start mode.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

o/c
30/4

Copy to:-

The Manager,

M/S Seema Lodge at 3745, Churiwalan, Chawri Bazar, Delhi- 06.