

c6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110 001**

No.F.6/DFS/MS/Educational/2024/SZ/ 84

Dated: 03/05/2024

To,

Authorised Signatory  
Shorting Hat Solutions Pvt. Ltd. (Unacademy),  
4, A-Block, Vikaspuri, New Delhi-110018.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Shorting Hat Solutions Pvt. Ltd. (Unacademy) at 4, A-Block, Vikaspuri, New Delhi- 110018.**

Sir

Please refer to your letter No. Nil, dated Nil, received in this department vide outdoor diary No. 122 dated 02.04.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Mr. Naveen was present and it was observed that the building is comprised of Basement (storage) Stilt (Parking), Upper ground & first floor (Coaching center), second & third floor (owner residence). Your request is rejected due to following shortcomings: -

1. Two staircases having width of 1.40 & 0.60 m found provided against requirements of two staircases with width of 1.50 m each.
2. Hose reel found provided but not functional
3. Internal hydrant system found provided but not functional.
4. Terrace fire pump capacity of 900 LPM found provided but not functional
5. Exit signage's are provided but not sufficient.

In view of above, issuance of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

  
(Abul Garg)  
Director  
Delhi Fire Service  
*del*

Copy to:-

Executive Engineer (Bldg) MCD, Civic Centre, Minto Road, New Delhi-110002.