

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/CGHS/SZ/2024/ 238

DATED: 06 10/5/2024

To,

The President,
AIMO CGHS Ltd.
Plot No - 11, Sector - 22,
Dwarka, New Delhi.

Subject: - Renewal of Fire Safety Certificate in r/o AIMO CGHS Ltd. Located at Plot No - 11, Sector - 22, Dwarka, New Delhi.

Sir,

Please refer to your Email, dated-02/04/2024 on the subject cited above. In this connection it is to inform you that the above said residential building has been inspected by the officer concerned of this department on 25/04/2024 in presence of Sh. Manoj Pal for fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Six meter wide internal road around the building found encroached / blocked.
2. Hose Reels & Hydrants found nonfunctional.
3. Terrace Pumps found nonfunctional.
4. Exit signage's found removed at some places.
5. Communication system in lift car found removed.
6. The passage to connect the blocks at terrace level found blocked/removed.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)
(Director)

Delhi Fire Service

Copy to:-1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.

9c
5/5/24