



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2024/WZ/ 212

Dated: 02/05/2024

To,  
The Principal,  
Beacon Global School,  
723, 724, Ext. Lal Dora, Pooth Khurd,  
Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Beacon Global School located at Plot No. 723, 724, Extended Lal Dora, Pooth Khurd, Delhi- 110039.

Sir,

This has reference to your email id dated 09/03/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 10.04.2024 to see the compliance of the requisite fire safety measures. Sh. Bhupender Dabas was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground and two upper floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. First Aid Hose Reel found not provided.
2. Terrace level pump of 450 lpm capacity not provided.
3. Overhead tank of 10,000 ltrs found not provided.
4. Exit signage's found not provided.
5. Sanctioned Building plan not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.

Handwritten initials and signature