

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/CGHS/SZ/2024/ 237

DATED: 06/05/2024

To,

The President,
Diesel Shed CGHS Ltd.
Plot No – 26, Sector – 10,
Dwarka, New Delhi.

Subject: - Renewal of Fire Safety Certificate in r/o Diesel Shed CGHS Ltd. Located at Plot No – 26, Sector – 10, Dwarka, New Delhi.

Sir,

Please refer to your letter No. Nil dated-07/04/2024 on the subject cited above. In this connection it is to inform you that the above said residential building has been inspected by the officer concerned of this department on 25/04/2024 in presence of Sh. Manbhawan from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Six meter wide internal road around the building found encroached / blocked.
2. Staircases found not clear/ partially blocked. at some places.
3. Only one ABC type 5kg capacity fire extinguisher was found provided against required two fire extinguishers at each floor.
4. One hose reel hose was operated and leakage was noticed at multiple places,
- 5 All the hose reel /Hydrants/ Hose fittings/Nozzle/ branched must be IS marked.
6. Exit signage's found removed at some places.
7. Communication system in lift car found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Yours faithfully,


(Atul Garg)
(Director)

Delhi Fire Service

Copy to:-1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.

OK

13/5/24