



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 208

Dated: 02/05/2024

To,

The Principal
Heaven Public School,
B- Block, Gali No-66, 25 Foota Road,
Sant Nagar, Burari, Delhi-110084.

Sub:- Regarding grant of fire safety certificate in r/o Heaven Public School at B- Block, Gali No-66, 25 Foota Road Sant Nagar, Burari, Delhi-110084.

Sir,

Please refer to your letter received through online e-mail dated 08.04.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 15.4.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors but school is running at ground plus 02 upper floors only. At the time of inspection Mr. Rajesh Kumar (Director) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. There is only one staircase provided width of 01m against the requirement of two staircases width of 1.50m each.
2. Hose reel hose not provided.
3. Pump capacity of 450 LPM with 40mtr head is not provided.
4. Overhead fire water tank capacity of 10,000ltr is not provided.
5. Exit signage is not provided at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director
Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.