

c/o 3

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2024/ 211

Dated: - 02/05/2024

To,

The Principal,
New Savitri Public School,
A-5, Sainik Enclave, Vikas Nagar,
Uttam Nagar, New Delhi- 110027.

Sub.: - Regarding issuance of Fire Safety Certificate in r/o New Savitri Public School at A-5, Sainik Enclave, Vikas Nagar, Uttam Nagar, New Delhi- 110059.

Sir,

With reference to your letter No. NSPS/2024 dated 26.03.2024, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 03.04.2024 in the presence of Mr. Vijay Kumar (Manager), to check the fire safety arrangements provided in the school building.

During the course of inspection, it was observed that the school building is comprised of ground floor plus three upper floors. Fire safety arrangements such as fire extinguishers found provided in the school building. However, the following shortcomings were observed: -

1. Two staircases having width of 1.20 & 1.0 mts found provided against requirement of two staircase and atleast one staircase having width of 1.50 mts.
2. First aid hose reel 01 Nos. at each floor found not provided.
3. Terrace fire pump capacity of 450 LPM found not provided.
4. Overhead water storage tank capacity of 10,000 lts found not provided.
5. Exit signage and floor marking at fire escape point found not provided.

In view of the above, issuance of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further necessary action in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
9cp

Copy to: -

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054.

For information please.