

c/04

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/NDZ/School/2024/ 207

Dated: 04/05/2024

To

The Principal,
Sarvodaya Bal Vidyalaya No. 1,
(Urdu Medium), Jama Masjid, Delhi- 06.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Sarvodaya Bal Vidyalaya No. 1, (Urdu Medium), Jama Masjid, Delhi- 06.

Sir,

This has reference to letter outdoor diary no. 13987 dated 07.03.2024 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 17.04.2024 in the presence of Mr. Ghyoor Ahmad (Principal) and observed that the building is comprised of basement + ground + 01 upper floor. During the inspection, following shortcomings still exists which issued earlier also vide letter no. F6/DFS/MS/School/2013/2434 dated 17/10/2013:-

1. Automatic sprinkler system in basement is not provided.
2. One terrace fire pump capacity of 450 LPM + 40 mtrs. head not provided.
3. Overhead water storage tank of capacity 5,000 ltrs. is required for sprinkler system.
4. Exit signages are not adequately provided.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,


(Atul Garg)

Director o/c

Delhi Fire Service

Tel: 011-23414000

19/4

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.