



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

098
T
कर्म
अमृत मंत्रालय

No. F 6 / DFS / MS / BP / 2024/218

Dated: 02 15 12024

To,

The Jt. Director (L&I) Bldg.
DDA, Vikas Sadan,
New Delhi.

Sub: Online Building plans in r/o revised sanction Drawing of Senior Secondary School belonging to Sri Venkateshwar Education Society, Sector-10, Dwarka, New Delhi.

Sir,

Please refer your online file No. DW10/0169/2023 dated 19/04/2024 on the subject cited above. In this connection this is to inform you that the referred online building plans have been examined and observed following shortcomings:

1. 6.0-meter-wide fire tender movement road all around the building is not proposed as per clause 8.2 of UBBL - 2016.
2. Width of main gate is not marked on the plan.
3. Plan of basement is not provided.
4. Fire Control Room is required as per clause 9.3.10 of UBBL – 2016, which is not proposed on the plan.
5. Staircases, serving from basement, are not segregated on ground floor.
6. Entry to staircases is not through Fire Check Doors as per clause 7.11 of UBBL-2016.
7. Entry to lift lobby is not through Fire Check Door as per clause 8.4.4 (i) of UBBL-2016.
8. Compartmentation is not proposed.
9. Staircases, serving from basement, are not segregated on ground floor.
10. Door/window schedule is not provided.
11. Fire-fighting arrangements, as stipulated in NBC-Part-4, 2016 are not marked on plans.

Therefore, plans are rejected.

Yours faithfully,


(ATUL GARG)
DIRECTOR
Ph. 011-23414000

अनु C 10