

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6 /DFS/MS/BP/2024/ 242

Dated: 07/05/2024

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi 110002.

Sub: Clearance from fire safety point of view in r/o Plot NO. – J-3B, Udyog Nagar Industrial Area, Rohtak Road, Delhi.

Sir,

Please refer your online request ID No.-10118544 dated 03/05/2024, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of new construction of building at Plot NO. – J-3B, Udyog Nagar Industrial Area, Rohtak Road, Delhi.

Following shortcoming is observed:

1. Staircases are not placed as per clause 7.8.3 of UBBL – 2016.
2. Terrace Pump is proposed 450 LPM against the requirement of 900 LPM as per NBC Part IV, 2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Garg)
Director

011-23414000

w e 2