



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/Industrial/SZ/2024/ 246

Dated: 08/05/2024

To

The Authorized Signatory,
M/s Sunil Rai And Co. Pvt. Ltd.,
Plot No. B-2/64, Mohan Co-operative Industrial Estate,
Mathura Road, Badarpur, New Delhi.

Sub: Regarding issuance of Fire Safety Certificate for M/s Sunil Rai And Co. Pvt. Ltd.,
located at Plot No. B-2/64, Mohan Co-operative Industrial Estate, Mathura Road,
Badarpur, New Delhi

Sir,

With reference to your letter no. nil dated 22.04.2024 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned from this department on 01.05.2024 in the presence of Sh. Kamlesh Kumar Mishra (Director) and it was observed that the building is comprised of Basement + Ground + 02 upper floors. During the inspection the following shortcomings were observed: -

1. Main staircase of width 1.50 meters not provided.
2. Fire check door (FCD) not provided.
3. Ventilation system in the basement not provided.
4. Manually Operated Electrical Fire Alarm (MOEFA) system not provided.
5. Standby pump (2280 LPM) & Jockey pump (180 LPM) not provided.
6. Lift lobby not provided.
7. Exit sinages not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

Atul R

Copy to:-

1. The Executive Engineer (Building), South DMC, 9th floor, Dr. SPM Civic Centre, JLN Marg, New Delhi.