

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2024/Hospital/ 958

Dated: 13/05/2024

To,

Mr. Sudhanshu Sharma,
Brahm Shakti Hospital,
U-1/78, Budh Vihar, Main Kanjhawala Road,
Delhi-110086

Sub: Issue of FSC in r/o M/s Brahm Shakti Hospital located at U-1/78, Budh Vihar, Main Kanjhawala Road, Delhi-86.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 14509 dated 21.03.2024 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **07.05.2024**, in presence of **Mr. Balram (Fire Officer)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Natural ventilation at upper floors found blocked at some places.
2. Exhaust fan found removed in basement.
3. FCD found removed in basement.
4. DG fire pump found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
[/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)
DIRECTOR

Ph; 011-23414000