

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/Hospital/2024/SZ/ 260

Dated: 13/05/2024

To,

The Director,
M/s Khanna Hospital,
C-2/396, Janakpuri, New Delhi-110058.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. M/s Khanna Hospital, situated at C- 2/236, Janakpuri, New Delhi- 110058.

Sir,

This has reference to your Letter No. Nil 'J' dated Nil, on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the hospital on 03.05.2024 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Vivek Khanna (M.D.) was present and it was observed that the hospital building is comprised of basement, ground plus three upper floors and have following shortcomings.

1. 02 staircase having width of 1.40 & 1.26 m found provided in basement and 02 staircase having width of 1.40 & 1.90 to 2.0 m found provided at ground floor to terrace level against requirement of 02 staircase having width of 2.0 & 1.50 m in basement to terrace level.
2. Fire check doors found not provided.
3. At third floor fire escape route found blocked (through a room).
4. Door width of 1.38 m found provided against required door width of 2.0 m.
5. Hose reels/hydrant found provided but not functional.
6. Heat/smoke detectors should be extended in left out area.
7. Sprinkler system should be extended in left out area.
8. Fire pumps found provided but not functional.
9. Exit Signes found not provided.
10. Fire Cartain found not provided in lift landing area.

Keeping in view of above, issuance of Fire Safety Certificate can-not be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. MS, Nursing Homes, DGHS, Govt of NCT of Delhi, S-1, 3rd Floor, School Block, Shakarpur, Delhi-110092.