



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/Industrial/SZ/2024 / 254

Dated: 10/05/2024

To

The Authorized Signatory,
M/s Mirkana Engineering Pvt. Ltd.,
A-19, MCIE, Mathura Road, Delhi-44.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Mirkana Engineering Pvt. Ltd., located at A-19, MCIE, Mathura Road, Delhi-44.

Sir,

With reference to letter bearing outdoor diary no. 08 dated 01.04.2024 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 03.05.2024 in the presence of Mr. Sunil (Manager) and it was observed that the building is comprised of 2 tier Basements + Ground + 02 upper floors + Half terrace covered with temporary/semi pacca construction for kitchen canteen, recreational activities and conference room. During the inspection following shortcomings were observed:

1. Two staircases of 2.0 meters width shall be provided.
2. Segregation of lift at all floors including basement shall be provided either by means of a lift lobby or fire curtain.
3. Ventilation system (Mechanical) in basement shall be synchronized with ADAS & MOEFA.
4. Ventilation (Natural or Mechanical) shall be provided at upper floors.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.