

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/Ind./2024/SZ/ 261

Dated: 13/05/2024

To

The Authorized Signatory,
Plot No. A-67, Okhla Industrial Area Phase-II,
New Delhi-110020

Sub: Regarding issuance of Fire Safety Certificate in r/o Plot No. A-67, Okhla Industrial Area Phase-II, New Delhi-110020

Sir,

This has reference with letter received through Outdoor diary no 1056 dated 25/04/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08.05.2024 in the presence of Mr. Naveen Sharma (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire Check door found removed in lift lobbies and door closing device also found removed.
2. Pressurization of lift lobbies and staircases are found removed.
3. Smoke ventilation system found removed in the basement.
4. Automatic detection system provided but found nonfunctional.
5. MOEFA not working.
6. Automatic sprinkler system provided but found nonfunctional.
7. Terrace level fire fighting pump capacity 900 LPM found removed and Fire Pumps are not on auto mode.
8. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE