

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6 /DFS/MS/BP/2024/ 239

Dated: 07/05/2024

To,

The Executive Engineer (Bldg.) HQ,  
Municipal Corporation of Delhi,  
9<sup>th</sup> floor, Civic Centre, Minto Road,  
New Delhi 110002.

Sub: Clearance from fire safety point of view in r/o Plot No. 111, Block A,  
Wazirpur Group Industrial Area, Delhi.

Sir,

Please refer your online request ID No.-10118474 dated 01/05/2024, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of new construction of building at Plot No. 111, Block A, Wazirpur Group Industrial Area, Delhi.

Following shortcoming is observed:

1. 06 meter wide along with 09m turning circle fire tender movement road is not proposed all around the high rise building as per clause 8.2 of UBBL – 2016.

Accordingly, the case is hereby rejected.

Yours faithfully,

  
(Atul Garg)  
Director  
011-23414000

W C