

C-45

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/SZ/2024/EH/173

Dated: 08/05/2024

To,

The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: - Renewal of Fire safety Certificate in r/o Beer on Wheels First floor unit no 110, 111, 112 City Centre Sector – 12, Dwarka New Delhi.


Sir,

Please refer to online application No. 2024041304995, dated 15/04/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the team of officers concerned from this department on 02/05/2024 in the presence of Sh. Rajesh Kumar (Supervisor) for fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. One exit door found closed.
2. Exit signage found removed at some places.
3. The restaurant activities are also seen in the open area not shown in the plan uploaded at MHA portal.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter


(Atul Garg)
Director
Delhi Fire Service

ok

Copy to: -

✓ The Manager, Beer on Wheels First floor unit no 110, 111, 112 City Centre Sector – 12,
Dwarka New Delhi