

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/ 94/219

DATED: 14/05/2024

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi

**Subject: - Renewal of Fire safety Certificate in r/o M/S Blisspoint Developers & Infrastructure Pvt. Ltd. Located at Ground, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floors Plot No.A-9, Naraina Vihar, New Delhi - 110028.**

Sir,

Please refer to online application No. 2024041204816, dated 16/04/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 06/05/2024 in the presence of Sh. Dinesh Shrivastav from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. The corridors/ passages found decorated by flammable material (Carpet flooring).
2. Ventilation system found nonfunctional/inadequate for upper floors & basement.
3. PA system found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. The Manager, M/S Blisspoint Developers & Infrastructure Pvt. Ltd. Located at Ground, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floors Plot No.A-9, Naraina Vihar, New Delhi - 110028.