

C-14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2024/197

Dated:- 06.05.2024

To,

The Manager,
M/S C.G. International Guest House,
3328, Gali Hari Mandir, Pahar Ganj,
New Delhi.

Sub: **Regarding issuance of FSC in r/o M/S C.G. International Guest House at 3328, Gali Hari Mandir, Pahar Ganj, New Delhi.**

Sir,

This has reference to online id no. ID NO 2024041305026 dated 14.04.24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned of this department on 25/04/2024 in the presence of Manager and following shortcomings were observed: -

1. CO detectors found nonfunctional.
2. PA system is not provided.
3. Stand by power supply not provided.

In view of above, the case is rejected with a request to rectify the shortcomings at the earliest for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service
25/4 dt

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.