

C-68

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ 198

Dated:- 06/05/2024

To,

The Manager,
M/S Hotel Magic Tree,
1826-1827, Laxmi Narayan Street,
Chuna Mandi, Pahar Ganj,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Hotel Magic Tree located at 1826-1827, Laxmi Narayan Street Chuna, Mandi, Pahar Ganj, New Delhi.

Sir,

This has reference to online id no. 2023041706641 dated 12.04.24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned of this department on 25/04/2024 in the presence of Manager and following shortcomings were observed: -

1. CO detectors found nonfunctional.
2. PA system found nonfunctional.

In view of above, the case is rejected with a request to rectify the shortcomings at the earliest for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

o/c

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.