

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 194

Dated: 06/05/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Hotel Rahul Palace, Located at 5/3, WEA Tank road, Ajmal khan road, Karol Bagh, New Delhi-110005.

Sir,

Please refer to online application No. 2024041204852, dated 12/04/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 29/04/2024 in the presence of Sh. Virender (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire Check Doors found not provided.
2. CO Detectors not provided in entire guest house.
3. Hose reel hose found nonfunctional.
4. MOEFA and PA system found not nonfunctional.
5. Automatic sprinkler system found nonfunctional in basement.
6. Terrace pump of 450 lpm capacity found nonfunctional.
7. Communication system in lift car found nonfunctional.
8. Electric panel installed in stairs must be shifted at another place away from stairs/passage.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: - The Manager, M/s Hotel Rahul Palace, Located at 5/3, WEA Tank road, Ajmal khan road, Karol Bagh, New Delhi-110005.