

c/15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/SZ/2024/ 176

Dated: 09/05/2024

To,

The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: - Issuance of Fire safety Certificate in r/o M/s Kandy (A unit of creative restaurant)
Located at H L Square, Plot No. 06, Sector -5 Dwarka New Delhi.

Sir,

Please refer to online application No. 2024041405055, dated 16/04/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the team of officers concerned from this department on 01/05/2024 in the presence of Sh. Remeshwaram (Restaurant Representative) for fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. Hose reel hose & hydrants found nonfunctional.
2. Automatic sprinkler system found nonfunctional.
3. MOEFA & PA system found nonfunctional.
4. Terrace pump of 450 LPM found nonfunctional.
5. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter

(Anul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Manager, M/s Kandy a unit of creative restaurant Located at H L Square, Plot No. 06, Sector -5 Dwarka New Delhi.