



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/ 165

dated: 06/05/2024

To

The Addl. Commissioner of Police,  
Lic Branch, 1<sup>st</sup> Floor, PS Defence colony,  
New Delhi -110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Locale (A Unit of Foursome Foods Pvt Ltd.) Shop No 17, Community Centre, Saket New Delhi 110017

Sir,

This has reference with **MHA Portal Id 2024032003349 dated 15-04-2024** on the subject cited above. In this concerned, it is to inform you that the premise was inspected by the concern nominated authority of this department on 30/04/2024 in the presence of Sh. Gurvinder Singh to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but found non-functional
2. Automatic sprinkler system provided but found non-functional.
3. Internal hydrant provided but found non-functional.
4. Fire fighting pumps provided but found not working.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

