

C-67

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/ 196

Dated: 06/05/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding issue of Fire Safety Certificate in respect of M/s Shan Guest House located at 753, Old Motor Market, Jama Masjid, Delhi - 06.

Sir,

This has reference to online application I.D. no. 2024041605340 dated 16.04.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned of this department on 02.05.2024 in the presence of Mohd. Alloudin (Manager) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. Fire extinguishers provided but non functional.
2. Hose reel hose provided but not functional.
3. CO detectors with panel and alarm system which are required as per Gazette Notification dated 27.05.2019, not provided.
4. Fire pump not in auto start mode.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Licensee, M/s Shan Guest House located at 753, Old Motor Market, Jama Masjid, Delhi - 06.

60 2/5 06/05