

e-110

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZI/2024/College/ 86

Dated:-07/05/2024

To

Prof. Narendra Singh (Principal),
Zakir Husain Delhi College (University of Delhi),
Jawahar Lal Nehru Marg, New Delhi-110002.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o Multistoried Academic Tower at Zakir Husain Delhi College Jawahar Lal Nehru Marg, New Delhi.

Sir,

This has a reference to your letter no. Nil dated 01.04.2024, on the subject cited above. In this regard, this is to inform you that the site was inspected by the officers concerned of this department on 29/04/2024 in the presence of Mr. Arpan Rites (AM) from building side and following shortcomings were observed:

1. 06 meter all around road for fire tender movement found obstructed due to branches of trees fall on the way.
2. Pressurization of staircase, lift lobby & shaft found nonfunctional.
3. Hose reel & hydrant found nonfunctional.
4. Smoke management system found nonfunctional.
5. PA system & MOEFA found nonfunctional.
6. Diesel Pump found nonfunctional and pumps also not in auto mode provision.

In view of above, the case is rejected with a request to rectify the above shortcomings immediately. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Ajul Garg)
DIRECTOR

01123414000

Copy to :

1. The Commissioner, MCD, Civic Center, New Delhi.