

C-67

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/NDZ/2024/ 214

Dated: 10/05/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Annapurna Guest House located at **680, Church Mission Road, Delhi – 06.**

Sir,

This is in reference to online application I.D. no.2024040103978 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned of this department on 06.05.2024 in the presence Manager and observed that the building is comprised of ground + 04 upper floors. During inspection, following shortcomings were observed:

1. Fire extinguishers due for refilling.
2. First aid hose reel found not functional.
3. CO detectors with panel and alarm system which are required as per Gazette Notification dated 27.05.2019, not provided.
4. Fire pump not in auto start mode.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 011-23414000
W 08/05
75

Copy to:-

The Licensee,

M/s Annapurna Guest House at 680, Church Mission Road, Delhi – 06.