

C-92

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/GH/204

Dated: 08/05/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/s Guest House Arihant Inn,
Located at 7A/69, WEA Channa market, Karol Bagh, New Delhi-110005.**

Sir,

Please refer to online application No. 2024040804471, dated 15/04/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 01/05/2024 in the presence of Sh. Manoj (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Smoke management system in basement found nonfunctional/inadequate.
2. MOEFA and PA system found not nonfunctional.
3. Terrace pump of 450 lpm capacity found nonfunctional on auto mode.
4. Communication system in lift car found removed.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

o/c
h
11/5/24

Copy to: - The Manager, M/s Guest House Arihant Inn, Located at 7A/69, WEA Channa market, Karol Bagh, New Delhi-110005.