

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ 9M/ 225

Dated:- 14/05/2024

To

The Manager
M/s Hotel High 5 Land at T-2344,
Faiz Road, Karol Bagh, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Hotel High 5 Land at T-2344, Faiz Road, Karol Bagh, New Delhi.

Sir,

This has a reference to Online id no. 2024040704377 dated 12.04.2024, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 01/05/24 in the presence of **Mr. Bhupender** and following shortcomings were observed.

1. Hose reel found nonfunctional.
2. CO detectors found nonfunctional.
3. PA system & MOEFA found nonfunctional.

In view of above, the case is rejected and Fire Safety Certificate cannot be renewed. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.