

478

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2024/ 94/226

DATED: 14/05/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate in r/o M/S Hotel Regency Located at 1st, 2nd & 3rd floors Plot No.15A/23, WEA Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2024041505115, dated 19/04/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 09/05/2024 in the presence of Sh. Surender (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Hose reel hose found nonfunctional.
2. Automatic sprinkler system found nonfunctional in basement.
3. PA system found nonfunctional.
4. Terrace pump of capacity 450 lpm found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)
Director,
Delhi Fire Service
13/5/24
11/05/24

Copy to:-

1. The Manager, M/S Hotel Regency Located at 1st, 2nd & 3rd floors Plot No.15A/23, WEA Karol Bagh, New Delhi - 110005.