

c/124

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ qh | 223

DATED: 14/05/2024

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi

**Subject: - Renewal of Fire safety Certificate in r/o M/S Hotel Sun View Located at 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floors Plot No.24B/9, WEA, Karol Bagh, D.B Gupta Road, New Delhi - 110005.**

Sir,

Please refer to online application No. 2024041805491, dated 18/04/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 06/05/2024 in the presence of Sh. Krishan Dev Shukla from fire safety point of view.

During the course of inspection following shortcomings were observed:

1. Hose reel hose system found nonfunctional.
2. MOEFA & PA system found nonfunctional.
3. Automatic sprinkler system found nonfunctional in basement.
4. Terrace pump of capacity 900 lpm found nonfunctional and not on auto mode.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,

(Anil Garg)  
Director,  
Delhi Fire Service.

Copy to:-

1. The Manager, M/S Hotel Sun View Located at 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floors Plot No.24B/9, WEA, Karol Bagh, D.B Gupta Road, New Delhi - 110005.