

C-82

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/ 212

Dated: 10/05/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s **Kastle Guest House** located at **J-1/16, Darya Ganj, Delhi.**

Sir,

This is in reference to online application I.D. no.2024042305915 dated 25.04.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned of this department on 06.05.2024 in the presence Mr. Chander Kishor (Manager) and it was observed that building is comprised of Basement + Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire check door which are required as per Gazette Notification dated 27.05.2019, not provided.
2. Exhaust fan for smoke management system not provided.
3. CO detectors with panel and alarm system which are required as per Gazette Notification dated 27.05.2019, not provided.
4. Fire pump not in auto start mode.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service o/c
Tel: 011-23414000

cc 7/5 8/5

Copy to:-

The Licensee,
M/s Kastle Guest House at J-1/16, Darya Ganj, Delhi.