

266

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/GH/217

Dated: 14/05/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Nand Kartar Orchid Suited guest house Located at Ground, 1st, 2nd & 3rd floor 15A/18, WEA Karol Bagh, New Delhi-110005.

Sir,

Please refer to online application No. 2024031503033, dated 16/04/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 04/05/2024 in the presence of Sh. Manoj Kumar (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire check door found not provided.
2. Ventilation found removed & atrium found covered.
3. CO detectors found not provided.
4. MOEFA found nonfunctional.
5. Terrace pump of 450 lpm capacity found nonfunctional on auto mode.
6. Basement found locked could not be inspected.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


13/05/24
(Atul Garg)

Director
Delhi Fire Service

Copy to: - The Manager, M/s Nand Kartar Orchid Suited guest house Located at, Ground, 1st, 2nd & 3rd floor 9A/34, Channa market, WEA Karol Bagh, New Delhi-110005.