



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2024/ 265
To,

Dated: 16/05/2024

Mr. Anil Wadhawan,
A-41, Mangol Puri, Block-A,
Industrial Area, Phase-II, Mangol Puri,
Delhi-110083.

Sub: Issue of FSC in r/o A-41, Mangol Puri Block-A, Industrial Area, Phase-II, Mangol Puri, Delhi-83.

Sir,

Kindly reference to online e-mail dated 10.04.2024 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **03.05.2024**, in presence of **Sh. Harpreet (Chest Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Auto closer of FCD found removed.
2. Alternated access is through lock and key of occupied area needs to be replaced with electric latches interconnected with smoke detector.
3. Smoke management system on 1st floor not found in auto mode nor interlinked with detection systems and ground floor smoke management system found blocked.
4. Door at terrace found replaced with shutter & ventilation of stair found blocked.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht
tp://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph: 011-23414000

