



No. F6 /DFS/MS/School/NDZ/2024/ 259

Dated: 21/05/2024

To,

The Principal,
Mac Angels Public School,
191, Street No.11, Chander Vihar,
I. P. Extension, Delhi - 110092.

Sub: - Regarding grant of Fire Safety Certificate in r/o Mac Angels Public School located at 191, Street No.11, Chander Vihar, I.P. Extension, Delhi - 110092.

Sir,

This has a reference to your outdoor diary no. 679 dated 15/04/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 10/05/2024 in the presence of Mrs. Ranjna Juneja (Principal) and observed that building comprised of ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. The width of staircase shall be 1.50 meter or an additional staircase of 0.90 meter shall be provided.
2. Fire extinguishers not provided.
3. First-Aid-Hose Reel not provided.
4. Fire pump of 450 LPM not provided.
5. Overhead tank capacity 10,000 liters not provided.
6. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Mac Angels Public School located at 191, Street No.11, Chander Vihar, I.P. Extension, Delhi - 110092.