



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5/24  
आजादी का  
अमृत महोत्सव

No. F6 /DFS/MS/School/NDZ/2024/ 255

Dated: 16/05/2024

To,

The Principal,  
Baalpan Public Model School located at F-280,  
Street No.10, Shastri Park,  
Delhi-110053.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Baalpan Public Model School located at F-280, Street No.10, Shastri Park, Delhi-110053.**

Sir,

This has a reference to your outdoor diary no. 338 dated 03/05/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/05/2024 in the presence of Mr. Baldev Raj Verma (Manager) and observed that building comprised of ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel provided but not functional.
2. Fire pump of 450 LPM not provided.
3. Overhead tank capacity 10,000 liters not provided.
4. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B- Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Baalpan Public Model School located at F-280, Street No.10, Shastri Park, Delhi-110053.