



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



Dated: 16/05/2023

No. F6/DFS/MS/2023/266

To,

The Authorized Signatory
Bhanot Bhawan, B-1/2,
Naniwala Bagh, Commercial
Complex, Azad Pur, Delhi-110033

Sub:- Regarding renewal of Fire Safety Certificate in r/o M/s Bhanot Bhawan located at B-1/2, Naniwala Bagh, Commercial Complex, Azad Pur, Delhi-110033.

Sir,

Please refer to your letter received through online e-mail dated 18.04.2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 11.05.2024 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Ramesh Kr. Rohilla (President) was also present at site. During the course of the inspection it is observed that the building is comprised of basement, ground, mezzanine & 03 upper floors only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Fire check doors found removed at some place.
2. Smoke ventilation system is found removed in the building.
3. Fire extinguisher is provided but not functional.
4. Hose reel hose is provided but not functional.
5. Automatic fire smoke detector system is provided but not functional.
6. MOEFA System is provided but not functional.
7. Sprinklers system is provided in the basement but found not functional.
8. Internal hydrant & yard hydrant is provided but not functional and badly damaged condition, also some hoses found removed at site.
9. Terrace level fire pump capacity of 900lpm provided but not functional.
10. Exit & floors signage's found removed at strategic location in the building.
11. Standby power supply not provided in the building.
12. Lose electrical cables inside the stairwell, which need to be proper conduit pipes.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph: 011-23414000

120/8