

C-80

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2024/250

Dated: 21/05/2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s Gulistan Guest House located at 3861, Khirki Taffazzul Hussain, Jama Masjid, Delhi - 06.

Sir,

This has reference to online application I.D. no. 2023060310215 dated 20.04.2024 on the subject cited above. In this connection, it is to inform you that guest house was visited by the officer concerned of this department on 08.05.2024 in the presence Mohd. Salim (Manager) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. Exhaust fan for smoke management system not provided.
2. Fire extinguishers provided but non functional.
3. CO detectors with panel and alarm system which are required as per Gazette Notification dated 27.05.2019, not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

10/05/2024  
14/5/2024

**Copy to:-**

The Manager,

M/s Gulistan Guest House located at 3861, Khirki Taffazzul Hussain, Jama Masjid, Delhi - 06.