



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 251

Dated: 16/05/2024

To

Smt. Amrita Kaur (Vice-Principal),
Guru Nanak Girls Sr. Sec. School at
Singh Sabha Road, Sabzi, Delhi-07.

Sub: - Regarding issuance of fire safety certificate in r/o Guru Nanak Girls Sr. Sec. School at
Singh Sabha Road, Sabzi, Delhi-110007.

Sir,

Please refer to your letter no. GN/P444/2024 dated 23.04.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 02.05.2024 to verify the fire safety measures issued vide NBC Pat-IV and observed that as per earlier shortcomings issued by this department letter of even no. F-6/DFS/MS/2018/School/2399 dated 08.06.2018 the building was comprised of ground & 02 upper floors only. At the time of inspection Smt. Amrita Kaur (Vice-Principal) was also present at site. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. First aid hose reel hose is not provided.
2. MOEFA system is not provided.
3. Terrace level fire pump capacity of 450lpm is not provided.
4. Terrace level fire fighting water tank capacity of 10,000ltr is not provided.
5. Exit signage and floor signage not provided at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.