

264



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ 232

DATED: 16/05/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate in r/o M/S Hotel Perfect Located at 2nd & 3rd floor Plot No.16A/2, WEA Karol Bagh, New Delhi 110005.

Sir,


Please refer to online application No. 2023050308128, dated 22/04/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 10/05/2024 in the presence of Sh. Naveen Pandey (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. One staircase found not clear/ partially blocked.
2. Fire check doors found not provided.
3. Hose reel hose found nonfunctional.
4. MOEFA found nonfunctional.
5. Automatic sprinkler system found nonfunctional.
6. Terrace pump found nonfunctional and not on auto mode.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


 (Atul Garg)
 Director,
 Delhi Fire Service.
 13/5/24

Copy to:-

1. The Manager, M/S Hotel Perfect Located at 2nd & 3rd floor Plot No.16A/2, WEA Karol Bagh, New Delhi 110005.