



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आज़ादी का
अमृत महोत्सव

C64

No. F6/DFS/MS/GH/SZ/2024/ 249

Dated: 17/05/2024

To

The Joint Commissioner of Police,
Office of Joint Commissioner of Police: Licensing,
1st Floor, P. S Defence Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Jashn's Inn Guest House located at Plot No. 50, Pocket-II, Jasola Vihar, New Delhi-25.

Sir,

With reference to the MHA online application no. 2024041605260 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 10.05.2024 in the presence of Mr. Vikas (Manager) and it was observed that the building is comprised of Basement (vacant) + Ground + 03 upper floors & Temporary construction on terrace floor. During the inspection following shortcomings were observed:

1. Temporary construction on terrace must be removed.
2. Hose reel found non functional.
3. Fire pump found non functional.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

14/5/24