

CS

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001

No. F6/DFS/MS/School/WZ/2024/ 237

Dated: 10/05/2024

To,

The Principal,
Kendariya Vidyalaya,
Tagore Garden, New Delhi – 110027.

Sub: - Renewal of Fire Safety Certificate in respect of Kendariya Vidyalaya located at Tagore Garden, New Delhi – 110027.

Sir,

This is in reference to your letter no. nil received through outdoor Diary No.- 14476 dated 21/03/2024 of this department, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 04/04/2024 in the presence of Sh. Dr. sanjay Kumar (Principal) to check the fire safety arrangements provided in the building.

During inspection, it was observed that the said school is running in total two blocks both are ground + two upper floors. The fire safety arrangements such as Fire Extinguishers, First-Aid Reels, etc are provided. However the following shortcomings were observed.

1. First-Aid Hose Reels are provided but not functional.
2. Terrace level pump capacity of 2 X 450 lpm is provided but not functional.
3. Overhead water storage tank capacity of 20,000 ltrs is provided but found empty.
4. Exit Signage's are found removed at some places.

In view of above Shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education, Old secretariat, Delhi – 110054.

06/05/2024