



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

2/02  
7/5  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 263

Dated: 21/05/2024

To  
The Principal,  
Lakshay Bharti School,  
E-16, AAli Vihar, New Delhi-76.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Lakshay Bharti School located at E-16, AAli Vihar, New Delhi-76.

Sir,

With reference to your letter no. LBS/01/2024-25 dated 18.04.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 10.05.2024 in the presence of Mrs. Neha (Incharge) and it was observed that the building is comprised of Basement + Upper Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. 2 nos. of staircases 1.50 meters width each not provided.
2. First aid hose reels not provided at each floor.
3. Automatic Sprinkler System not provided in basement (area more than 200 m<sup>2</sup>).
4. Fire pump of 900 LPM with head 40 m not provided.
5. Terrace water tank of 15,000 liters not provided (exclusively for firefighting).
6. Exit signages not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

11/5/24

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.